



INSPECTION CRITERIA

For external architectural application the observation distance is 3 meters for ground floors and 5 meters for higher floors.